

UNINSTALLED -- AFFF in manufacturers shippin

Region	Installation Name	Special Area Name	Owning BSO (CNIC, DLA, NAVSUP, NAVSEA, etc)	DODAAC	UIC	Bldg #
CNRNW	NBK Manchester	n/a	CNIC	N61134	61134	12
CNRNW	NAS Whidbey	n/a	CNIC	N00620	00620	2897
CNRNW	Boardman	n/a	CNIC	N61137	61017	41
CNRNW	NS Everett	n/a	CNIC	N68967	68967	2110
CNRNW	NBK Jackson Park	n/a	CNIC	N32416	32416	83
CNRNW	NBK Manchester	n/a	CNIC	N61134	61134	12

g containers (cans, pails, drums, or totes).

Facility Name (Fire Sta 1, Fire, F&ES Storage, Hanger 1, HazCenter)	Physical Address	Storage, Trucks/Trailers (Uninstalled)
Storage Building	7501 Beach Drive East, Bldg. 12, Port Orchard, WA. 98366	Ready Reserve
Fire Station 71	3680 N. Ranger St. Oak Harbor, WA 98278	Ready Reserve
F&ES Storage	76966 Bombing Range Rd. Boardman, OR 97818	Ready Reserve
F&ES Storage	2000 West Marine View Dr. Everett, WA. 98207	Ready Reserve
Storage	83 Olding RD; Bremerton, WA	Ready Reserve
Storage	12 Olympic Drive; Manchester, WA	Ready Reserve

Truck Name/Number	USN	AFFF Manufacture	Class/Type Foam	Percentage
n/a	n/a	3M COMPANY	Class B (AFFF)	3%
n/a	n/a	BUCKEYE	Class B (AFFF)	3%
n/a	n/a	Baum's (Novacool)	Class A and B	3%
n/a	n/a	BUCKEYE	Class B (AFFF)	3%
n/a	n/a	ANSUL	Class B (AFFF)	3%
n/a	n/a	ANSUL	Class B (AFFF)	3%

Nomenclature / Trade Name	Foam Formulation (PFOS, PFOA, C6, Other)	Date Manufactured	Expiration Date
3M Light Water AFFF	PFOS/PFOA	30-Jun-00	30-Jun-25
BUCKEYE 3% MIL SPEC AFFF	UNK IF IT Contains PFOA	1-Jun-09	1-Jun-34
NOVACOOOL UEF	UNK IF IT Contains PFOA	1-Jul-14	1-Jul-24
BUCKEYE 3% MIL SPEC AFFF	UNK IF IT Contains PFOA	1-Jun-09	1-Jun-34
ANSULITE 3% AFFF (AFC-3MS) (C6)	C6	1-Aug-16	1-Aug-41
ANSULITE 3% AFFF (AFC-3MS) (C6)	C6	1-Aug-16	1-Aug-41

Number of 5 gallon Cans/Pails	Number of 55 gallon Drums	Tote Size (gallons)	Number of Totes	Dispensing Tanks Capacity (gallons)
0	40	0	0	
0	22	0	0	
70	0	0	0	
11	0	0	0	
100	0	0	0	
0	45	0	0	

Total Quantity Uninstalled (gallons)	Quantity Installed Vehicle Tanks (gallons)	Original Amount Reported N30 (gallons)	Date AFFF Tested	Last date AFFF Discharge Test was performed on this vehicle? (Month/Year)
2,200		85	Not Tested	
1,210		70	Not Tested	
350		70	Not Tested	
55		80	Not Tested	
500		2,200	Not Tested	
2,475		2,200	Not Tested	

6,790

Was the AFFF discharge test contained in an approved containment facility?	Estimated quantity (gallons) of AFFF solution released	Site / location description.

Was reclamation action taken to removed and disposed of AFFF contaminated soils?	5-Gal Drums	55-Gal Drums	220- or 275-Gal Totes
	0	40	0
	0	22	0
	70	0	0
	11	0	0
	100	0	0
	0	45	0

CNIC USE ONLY

Other (Describe)	Empty Totes Ordered (275- gal)	5-Gal Drums	55-Gal Drums	275-Gal Totes
0				
0				
0				
0				
0				
0				



Other (Describe)	5-Gal Drums	55-Gal Drums	275-Gal Totes	Other (Describe)