

POCs:

(b) (6), NAVFAC Environmental Compliance Programs, (b) (6).

Joe Simone, NAVFAC Chief Fire Protection Engineer, (b) (6)

Directions/Rules of Engagement:

INSTALLED AFFF FIXED SYSTEMS -- AFFF installed in fixed fire protection systems.

1. This datacall when complete should document all INSTALLED AFFF in fixed fire protection systems (Buildings, Hangers, Flammable Liquid Storage Sites, etc.).
2. Inventory ONLY AFFF firefighting foams installed in fixed fire suppression system tanks.
3. Use pull down menu(s) before typing. If the choice is not available enter the complete nomenclature as written on the product container and click "Yes" on the pop-up warning message.
4. Use your best judgment as to the brand of AFFF in the tank.
5. Use the tank capacity or ESTIMATE the amount of AFFF (gallons) in the tank...it is NOT necessary to drain tanks in order to determine the amount.
6. Determine the total amount (gallons) of each fixed system tank by the facilities and/or tank location documenting the AFFF brand name, class, percentage.

- Add a new row for each "AFFF tank"

CNIC/NAVFAC will total each Region input for the Enterprise totals for each "brand name, class, percentage, by location" and coordinate disposal strategy with DLA Disposition Services.